



Standard Non Combustible threshold

- 10mm (max) gap

Note: If smoke control is required then max gap is 3mm or drop seal fitted

Flush Hardwood Threshold - 640kg/m³ (min)

- 10mm (max) gap
- 15mm (min) thick threshold.
- Threshold must be 9mm (min) wider than door leaf at each face
- 20 x 4mm intumescent strip in base of door leaf

Note: If smoke control is required then max gap is 3mm or drop seal fitted

Flush Hardwood Threshold - 640kg/m³ (min)

- 10mm (max) gap
- 15mm (min) thick threshold.
- Threshold must be 9mm (min) wider than door leaf at each face
- Drop down seal must be fitted with 20 x 2mm graphite strip to each vertical edge of drop down seal body

Aluminum Threshold Plate

- 4mm (max) gap between top of aluminum threshold plate & base of door
- Must be bedded with 2mm interdens protection inserted in floor for full footprint of aluminum threshold plate
- Aluminum threshold plate to finish against frame and door stops cut to fit over strip
- Aluminum threshold plate to be no more than 6mm in height from FFL

Note: If smoke control is required then max gap is 3mm or drop seal fitted

Rev:	Date:	Initial:	Checked:
0	12.01.22	DC	-