



FIRE RESISTANT PARTITION SYSTEMS

Certificate number: IFCC 1892

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd part of the Kiwa UK Group

This is to certify that

Forza Doors Ltd

Star Road Trading Estate,
24a/24c Star Road
Partridge Green
Horsham
RH13 8RA

Who fabricate the following fire-resistant glazed timber screens:

Fire Screen Imola Screen

have successfully completed the requirements of the SDP 21 (Partitions) scheme. This includes the testing of products to **BS 476: Part 22: 1987** the inspection of their Factory Production Control and continuing surveillance assessments and testing of samples of products taken from production. The product specification and field of application to achieve from **30 to 60 minutes integrity** is detailed in page 2 of this certificate.


Initial Certification: 17 January 2024

Valid to: 16 January 2029

Issue number: One

David Mowatt
Head of Certification – IFC Certification /
KIWA Group Limited.

*This certificate consists of 2 pages.
Publication of this certificate is permitted.*



The production of fire-resistant glazed partitioning systems are manufactured in accordance with assessment/ test reports referenced within the following table:

Description	Fire Rating	Assessment/Test Report
Fire Screen	30 & 60 mins	PAR/11294/01
Imola Screen	30 mins	PAR/11294/01

Signed on behalf of Kiwa UK

David Mowatt
Head of Certification – IFC Certification /
KIWA Group Limited

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder’s responsibility to ensure that the latest versions/ revisions of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.

CERTIFICATE

