

IMOLA G2G SINGLE GLAZED

12.8 ACOUSTIC GLASS


LISG12.8.37ASG2G

Rating according to BS EN ISO 717-1:2013

Rw(C:Ctr)= 37 (-1:-2) dB



Test Number:	6	Air Temperature (°C):	10.8
Testcentre/Client:	FORZA	Air Humidity (%):	81
Test Date:	24/1/2018	Receiving room Volume (m³):	50
specimen test area m2	10.33	Source Room volume (m3):	55
		Sample weight (kg/m²):	30
Product:	Head and perimeter track MC.01. Base track MC10.Beads MC03 & MU11 Glass to Glass "I" joint GlazingGaskets STGT9A & STGT9W		
Identification:	FIS-T-G-3640-FO-A		



Notes	+ designates frequency beyond standard and not UKAS accredited
	*designated measurement corrected for background



forza-doors.com
01403 711 126
tech@forza-doors.com