


FORZA REFERENCE

SG54.35A60GS

Rating according to BS EN ISO 717-1:2013

Rw(C:Ctr)= 35 (-1:-2) dB

Test Number:	26	Air Temperature (°C):	15.3
Testcentre/Client:	STS	Air Humidity (%):	69
Test Date:	29/04/2014	Receiving room Volume (m³):	300
Sample height (m):	2.13	Source Room volume (m³):	115
Sample width (m):	1	Sample weight (kg/m²):	40.2
Product:			
Identification:	54mm Timber particle board core / mdf face door with 16mm GFP glass in a hardwood frame		
	Seals : Head & Jambs - ST1009 / 2no. 15 x 4mm intumescents		
	Threshold - ST422		



Notes	+ designates frequency beyond standard and not UKAS accredited
	# designates measurement corrected for background (dB at 10000+ Hz)

SEP-24



forza-doors.com
01403 711 126
tech@forza-doors.com